



Certificate of Compliance

Certificate: 70040689 (170351)

Master Contract: 170351

Project: 70040689

Date Issued: 2015-07-31

Issued to: **Bel Fuse Inc.**
206 Van Vorst St
Jersey City, New Jersey 07302
USA

Attention: Editha S. Vergara

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Issued by: Juan-Carlos Olivera,
MSc.

PRODUCTS

CLASS – 5311 11 - POWER SUPPLIES - Component Type (CSA 60950-1-07-2nd Ed)

CLASS – 5311 91 - POWER SUPPLIES - Component Type (UL 60950-1-2nd Ed) - Certified to U.S. Stds

For details related to rating, size, configuration, etc. reference should be made to the CSA Certification Record or the descriptive report.

Component type power supplies intended for use with Information Technology and Business Equipment, where the suitability of the combination is to be determined by CSA Group.

AC/DC Switching Power Supply, model LPM616 Series; rated Input: 100-240 V ac, 15.3 -6.4 A, 50-60 Hz or 140-380 V dc, 11.1 – 4.0 A; Output: maximum 1300 W or Input: 200-240 V ac, 9.2-7.6 A, 50-60 Hz or 210-380 V dc, 9-4.9A; Output: Maximum 1600 W; specified as follows:

LPM	6	16	-	E	F	G	H	I	J	-	X
I	II	III				IV					V

I – Model Series: LPM

II – Number of slots: 6



Certificate: 70040689
Project: 70040689

Master Contract: 170351
Date Issued: 2015-07-31

III – Maximum Output Power:

16 = 1600 W

IV – Output Modules:

Module	Model Name	Nominal Output Voltage (V dc)	Voltage Range (V dc)	Maximum Output Current (A)	Maximum Output Power (W) *
E	LPM126-OUTA1-5	5	2.0 to 5.3	53	265
F	LPM126-OUTA1-12	12	5.2 to 15	22	265
G	LPM126-OUTA1-24	24	14 to 30	11	265
H	LPM126-OUTA1-36	36	29 to 44	7.4	265
J	LPM126-OUTA1-48	48	43 to 54	5.5	265
K	LPM109-OUTA1-10	10	1.5 to 15	6	90
L	LPM109-OUTA1-20	20	3 to 32	3	90
M	LPM118-OUTA2-10	10	2x 1.5 to 15	2x 6	2x 90
N	LPM118-OUTA2-20	20	2x 3 to 32	2 x 3	2x 90
0	-	Blank Panel Slot Cover			

Note: Any module may be placed on any slot location.

*Maximum output power of modules are derated based on operating ambient and input voltage. See below for details:

- 1) Module E: LPM126-OUTA1-5
 Maximum 225 W for input voltage from 85-150 Vac, 40°C ambient
 Maximum 175 W for input voltage from 85-264 Vac, 50 to 70°C ambient
- 2) Module F, G, H: LPM126-OUTA1-12, LPM126-OUTA1-24, LPM126-OUTA1-36
 Maximum 225 W for input voltage from 85-150 Vac, 50°C ambient
 Maximum 175 W for input voltage from 85-264 Vac, 70°C ambient
- 3) Module K, L: LPM109-OUTA1-10, LPM109-OUTA1-20
 Maximum 45 W for input voltage from 85-264 Vac, 70°C ambient
- 4) Module M,N; LPM109-OUTA2-10, LPM118-OUTA2-20
 Maximum 90 W for input voltage from 85-264 Vac, 70°C ambient

V – Optional Suffixes (denoting non-safety critical options)



Certificate: 70040689

Project: 70040689

Master Contract: 170351

Date Issued: 2015-07-31

APPLICABLE REQUIREMENTS

- | | |
|---|--|
| CAN/CSA-C22.2 No 60950-1-07,
+Am.1:2011 +Am.2:2014 | – Information Technology Equipment - Safety - Part 1: General Requirements |
| UL 60950-1-2014 | – Information Technology Equipment - Safety - Part 1: General Requirements |

CONDITIONS OF ACCEPTABILITY

1. The power supply is to be installed only by trained service personnel, according to manufacturer installation instructions.
2. Evaluated for use in Pollution Degree 2 Environment, for a maximum ambient temperature of 50°C, full load and 70°C at 50% load.
3. Temperature tests shall be considered for specific installation conditions in the end system.
4. Evaluated as Class I (earthed equipment). Reliable connection to protective earth shall be provided in the end use installation.
5. Spacings were evaluated for an operating altitude of max 10,000 ft (3048 m), based on IEC-60664-1 altitude correction factor.
6. Evaluated for connection to AC power with a branch circuit protector rated max 50 A. If used on a branch circuit with higher rating, additional testing shall be considered.
7. The front bezel has been evaluated and found compliant with requirements for FIRE, MECHANICAL and ELECTRICAL enclosure. Overall enclosure suitability is to be determined in the end system.
8. Output circuits in all modules are SELV and at hazardous energy levels (240 VA).
9. The input terminal block is suitable for field wiring.
10. The output connector was evaluated and suitable only for factory wiring.



Supplement to Certificate of Compliance


Certificate: 70040689 (170351)

Master Contract: 170351

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
70040689	2015-07-31	AC/DC Switching Power Supply, Model LPM616 Series. (C/US) (transferred from 173688 - 2556198 and upgraded to include Am2).

Product	AC/DC or DC/DC switching power supply
Applicant	Bel Fuse Inc. 206 Van Vorst St. Jersey City, NJ 07302 USA
Manufacturer	Bel Fuse Inc. 206 Van Vorst St. Jersey City, NJ 07302 USA
Factory	<input checked="" type="checkbox"/> See page 2
Ratings	Input: A) 100-240Vac, 15.3-6.4A, 50-60Hz or 140-380Vdc, 11.1-4.0A B) 200-240Vac, 9.2-7.6A, 50-60 Hz or 210-380 Vdc, 9.0-4.9A
Trade mark	 a bel group
Model / Type Ref.	LPM616 Series
Principal characteristics	Output(s): DC: A) 1300W maximum B) 1600 W Maximum <input type="checkbox"/> See next page(s)
A sample of the product was tested and found to be in conformity with	OFF EN 60950-1:2006;A11;A1;A12;A2
Validity	This certificate documents conformity with the standards shown, and also applies as license for use of Nemkos name and certification mark. The certificate and license is valid as long as the applicable conditions are complied with, and provided that any changes to the product are notified to Nemko for acceptance prior to implementation. New standards or amendments to the standards may imply that the product design must be updated and/or that re-testing and re-certification is necessary.
Additional information	<input type="checkbox"/> See next page(s) The abovementioned certified equipment complies with current regulatory requirements regarding electrical safety in Norway and other EU/EEA member states, as far as this can be checked. Compliance with requirements regarding building-in, protection against electric shock and Electromagnetic Compatibility (EMC) must be checked when the equipment is built-in a completed product or forms a part of a complete system.
Additional model(s)	<input type="checkbox"/> See next page(s)

Date of issue 21-09-2015



Juan Z. Kleppenes
Certification Department

Nemko AS

Gaustadalléen 30, P.O. Box 73 Blindern, 0314 Oslo, Norway
TEL +47 22 96 03 30 FAX +47 22 96 05 50 EMAIL info@nemko.com
ENTERPRISE NUMBER NO974404532

Factories:

Avnet Technology Solutions
6700 W MORELOS PL
CHANDLER, AZ 85226
USA

Bel Power Solutions, s.r.o.
Areal ZTS 924
01841 Dubnica nad Vahom
Slovakia

Sonitrones S A De CV Arrow Electronics Inc
Blvd Luis Donaldo Colosio #1179
84048 Nogales
Mexico

Master Electronics
610 East 10th Street
Oakland, CA 94606
USA

Date of issue 21-09-2015



Juan Z. Kleppenes
Certification Department

Nemko AS

Gaustadalléen 30, P.O. Box 73 Blindern, 0314 Oslo, Norway
TEL +47 22 96 03 30 FAX +47 22 96 05 50 EMAIL info@nemko.com
ENTERPRISE NUMBER NO974404532

CB TEST CERTIFICATE CERTIFICAT D'ESSAI OCProduct
Produit

AC/DC or DC/DC switching power supply

Name and address of the applicant
Nom et adresse du demandeurBel Fuse Inc.
206 Van Vorst St.
Jersey City, NJ 07302
USAName and address of the manufacturer
Nom et adresse du fabricantBel Fuse Inc.
206 Van Vorst St.
Jersey City, NJ 07302
USAName and address of the factory
Nom et adresse de l'usineNote: When more than one factory, please report on page 2
Note: Lorsque il y plus d'une usine, veuillez utiliser la deuxième page Additional information on page 2Ratings and principal characteristics
Valeurs nominales et caractéristiques principalesInput: A) 100-240Vac, 15.3-6.4A, 50-60Hz or 140-380Vdc, 11.1-4.0A
B) 200-240Vac, 9.2-7.6A, 50-60 Hz or 210-380 Vdc, 9.0-4.9ATrademark (if any)
Marque de fabrique (si elle existe)Type of Manufacturer's Testing Laboratories used
Type de programme du laboratoire d'essais constructeur

LPM616 Series

Model / Type Ref.
Ref. De type

Additional information (if necessary may also be reported on page 2)

Output(s): DC: A) 1300W maximum B) 1600 W Maximum

Les informations complémentaires (si nécessaire, peuvent être indiqués sur la deuxième page)

 Additional information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60950-1(ed.2);am1;am2

Un échantillon de ce produit a été essayé et a été considéré conforme à la

As shown in the Test Report Ref. No. which forms part of this Certificate

291976

Comme indiqué dans le Rapport des essais numéro de référence qui constitue partie de ce Certificat

This CB Test Certificate is issued by the National Certification Body
Ce Certificat de essai OC est établi par l'Organisme **National de Certification**Gaustadalléen 30
NO-0373 Oslo, Norway

Date: 21-09-2015

Signature: Juan Z. Kleppenes
Certification Department

Avnet Technology Solutions
6700 W MORELOS PL
CHANDLER, AZ 85226
USA

Sonitrones S A De CV Arrow Electronics Inc
Blvd Luis Donaldo Colosio #1179
84048 Nogales
Mexico

Bel Power Solutions, s.r.o.
Areal ZTS 924
01841 Dubnica nad Vahom
Slovakia

Master Electronics
610 East 10th Street
Oakland, CA 94606
USA



Gaustadalléen 30
NO-0373 Oslo, Norway


Date: 21-09-2015

A handwritten signature in blue ink that reads "Juan Z. Kleppenes".



Signature: Juan Z. Kleppenes
Certification Department



<p>TEST REPORT IEC 60950-1 Information technology equipment – Safety – Part 1: General requirements</p>	
Report Number :	291976
Date of issue.....:	17 September, 2015
Total number of pages	70
Applicant's name	Bel Fuse Inc.
Address.....:	206 Van Vorst St., Jersey City, NJ 07302
Test specification:	
Standard	IEC 60950-1:2005 (Second Edition) + Am 1:2009 + Am 2:2013
Test procedure.....:	CB-Scheme
Non-standard test method.....:	N/A
Test Report Form No.	IEC60950_1F
Test Report Form(s) Originator	SGS Fimko Ltd
Master TRF	Dated 2014-02
<p>Copyright © 2014 IEC System of Conformity Assessment Schemes for Electrotechnical Equipment and Components (IECEE System). All rights reserved.</p> <p>This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.</p> <p>This report is not valid as a CB Test Report unless signed by an approved CB Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with IECEE 02.</p>	
General disclaimer:	
<p>The test results presented in this report relate only to the object tested. This report shall not be reproduced, except in full, without the written approval of the Issuing CB Testing Laboratory. The authenticity of this Test Report and its contents can be verified by contacting the NCB, responsible for this Test Report.</p>	

Test item description	AC/DC or DC/DC switching power supply
Trade Mark	 <small>a bel group</small>
Manufacturer	Same as Applicant
Model/Type reference	LPM616 Series
Ratings	<u>Input:</u> A) 100-240 Vac, 15.3-6.4 A, 50-60 Hz or 140-380 Vdc, 11.1-4.0 A B) 200-240 Vac, 9.2-7.6 A, 50-60 Hz or 210-380 Vdc, 9.0-4.9A <u>Output(s), DC:</u> A) 1300 W maximum B) 1600 W maximum

Testing procedure and testing location:

Testing procedure and testing location:	
CB Testing Laboratory:	Nemko USA Inc.
Testing location/ address	2210 Faraday Ave. Suite 150, Carlsbad, CA 92008, USA
Associated CB Testing Laboratory:	
Testing location/ address	
Tested by (name + signature)	George Daverin 
Approved by (name + signature)	Jeff Busch 

Report History:

Original report

- List of Attachments (including a total number of pages in each attachment):**
- Attachment 1: European Group Differences and National Deviations 81 pages
 Documented deviations contain individual national documents for several European countries that are included in the European Group Deviations. The European Group Difference: EN60950:2006/A11:2009/A:2010/A12:2011/A2:2013 are considered "Normative". The individual national documents (Denmark, Finland, Germany, Ireland, Norway, Spain, Sweden, Switzerland and United Kingdom) are considered "informative" and included at the manufacturer's request.
 - Attachment 2: Miscellaneous Documentation, e.g. Photos, PWB Layout, Schematic etc. 60 pages
 (Not for publication – Engineering use only)

Summary of testing	
General	All comments relate to all models, unless specifically stated.
Power supply	The equipment is an enclosed, Class I switch mode power supply with universal AC input or DC input and multiple DC voltage outputs for building-in. This report covers multiple models and all comments / tests apply to all models unless otherwise indicated. Testing was conducted on various models as indicated.
1.1.2; The unit is intended to operate at an altitude of up to 3048m.	This equipment is intended to be operated at an altitude of up to 3048 m so the clearance is multiplied by the altitude correction factor (1.15), specified in table A.2 of IEC 60664-1 2 nd Edition:2007-04. Refer to Tables 2.10.3 and 2.10.4.
1.7.2; Safety instructions.	Instructions and equipment markings related to safety are to be provided in a language, which is acceptable in the country in which the equipment is to be sold. English language verified.
1.7.2.4; IT power distribution systems.	The equipment complies with the requirements for connection to the Norwegian IT power systems. The following information should be given (but is not required) in the installation instruction: "This product is also designed for IT power system with Phase to Phase voltage 230V."
2.7.4; Number and location of protective devices.	In Norway, IT power distribution system is used. Equipment with a single protective device is accepted in Norway. Other countries may have additional requirements.
2.7.6; Warning to service personnel.	After operation of the protective device, the equipment is still under voltage if it is connected to an IT-power system. A warning is required for service personnel. Norway does not require this warning.
5.2: Electric Strength test	Increased test voltages for Basic insulation applied to the equipment, based on measured working voltages.

Summary of testing:	
Tests performed (name of test and test clause): 1) Input Test 1.6.2 2) Durability Test 1.17.11 3) Capacitance Discharge Test 2.1.1.7 4) Energy Hazard DC Mains 2.1.1.8 5) SELV Reliability Test 2.2 6) Protective Bonding Test 2.6.3.4 7) Humidity Test 2.9.2 8) Working Voltage Measurement 2.10.2 9) Hazardous Voltage Measurement 2.10.2 10) Heating Test 4.5.1 11) Touch Current Test 5.1 12) Electric Strength Test 5.2.2 13) Component Failure Test 5.3 14) Abnormal Operation Test 5.3 15) PS Output Overload and Short Test 5.3 16) Transformer Overload Annex C 5.3	Testing location: See page 2

Summary of compliance with National Differences:
List of countries addressed Austria (AT), Australia (AU), Canada (CA), China (CH), Denmark (DK), Finland (FI), Germany (DE), Ireland (IE), Israel (IS), Korea (KR), Norway (NO), Slovenia (SI), Spain (ES), Sweden (SE), Switzerland (CH), United Kingdom (GB), United States of America (US)
<input checked="" type="checkbox"/> The product fulfils the requirements of : EN 60950-1:2006 + A11:2009 + A1:2010 + A12:2011 + A2:2013

Copy of marking plate: The artwork below may be only a draft. The use of certification marks on a product must be authorized by the respective Certification Bodies that own these marks.

AC-DC Converter		LPM616-RRRRRRR-YYYYY				
INPUT: ~ 100–240V 15.3–6.4A 50-60Hz		DC OUTPUT: 1300W				
== 140–380V 11.1–4.0A		DC OUTPUT: 1300W				
~ 200–240V 9.2–7.6A 50-60Hz		DC OUTPUT: 1600W				
== 210–380V 9.0–4.9A		DC OUTPUT: 1600W				
OUTPUTS:	SLOT 1	SLOT 2	SLOT 3	SLOT 4	SLOT 5	SLOT 6
C-XXXXX	== nnV/pppW	== nnV/pppW	== nnV/pppW	== nnV/pppW	== nnV/pppW	== nnV/pppW
POWER SOLUTIONS & PROTECTION <small>a bel group</small>					B zzzzzzzz U uuuuuu Rev. vv(v) Lxx Wyyww Made in mmm	

Calibration	All instruments used in the tests given in this test report are calibrated and traceable to national or international standards. Further information about traceability will be given on request.
Measurement uncertainty	Measurement uncertainties are calculated for all instruments and instrument set-ups given in this report. Calculations are based on the principles given in the standard EA-4/02 (Dec. 1999), IEC Guide 115:2007, Nemko routine L227 and other relevant internal Nemko-procedures. Further information about measurement uncertainties will be given on request.
Evaluation of results	If not explicitly stated otherwise in the standard, the test is passed if the measured value is equal to or below (above) the limit line, regardless of the measurement uncertainty. If the measured value is above (below) the limit line, the test is not passed - ref IEC Guide 115:2007, and Nemko routine L220. The instrumentation accuracy is within limits agreed by IECCE-CTL (ref. Nemko routine L227).

Test item particulars:	
Equipment mobility	<input type="checkbox"/> movable <input type="checkbox"/> hand-held <input type="checkbox"/> transportable <input type="checkbox"/> stationary <input checked="" type="checkbox"/> for building-in <input type="checkbox"/> direct plug-in
Connection to the mains.....	<input type="checkbox"/> pluggable equipment <input type="checkbox"/> type A <input type="checkbox"/> type B <input checked="" type="checkbox"/> permanent connection <input type="checkbox"/> detachable power supply cord <input type="checkbox"/> non-detachable power supply cord <input type="checkbox"/> not directly connected to the mains <input checked="" type="checkbox"/> DC mains
Operating condition	<input checked="" type="checkbox"/> continuous <input type="checkbox"/> rated operating / resting time:
Access location	<input checked="" type="checkbox"/> operator accessible <input type="checkbox"/> restricted access location <input checked="" type="checkbox"/> Equipment for building, to be evaluated in end-use equipment.
Over voltage category (OVC)	<input type="checkbox"/> OVC I <input checked="" type="checkbox"/> OVC II <input type="checkbox"/> OVC III <input type="checkbox"/> OVC IV <input type="checkbox"/> other:
Mains supply tolerance (%) or absolute mains supply values	AC Input: 90 to 264 Vac DC Input: 140 to 380 Vdc
Tested for IT power systems	<input checked="" type="checkbox"/> Yes (Norway only) <input type="checkbox"/> No
IT testing, phase-phase voltage (V)	230
Class of equipment	<input checked="" type="checkbox"/> Class I <input type="checkbox"/> Class II <input type="checkbox"/> Class III <input type="checkbox"/> Not classified
Considered current rating of protective device as part of the building installation (A)	30A
Pollution degree (PD)	<input type="checkbox"/> PD 1 <input checked="" type="checkbox"/> PD 2 <input type="checkbox"/> PD 3
IP protection class	IPX0
Altitude during operation (m)	3048 m
Altitude of test laboratory (m)	38
Mass of equipment (kg)	1.92 kg
Temperature, Ambient (°C).....	40°C or 50°C at full load 70°C with 50% load

Possible test case verdicts:	
- test case does not apply to the test object.....	N/A
- test object does meet the requirement.....	P (Pass)
- test object does not meet the requirement	F (Fail)

Testing.....	
Date of receipt of test item	July 2015
Date (s) of performance of tests.....	August 2015

General remarks:

"(see appended table)" refers to a table appended to the report.
 "(see Enclosure #)" refers to additional information appended to the report.
 The test results presented in this report relate only to the object tested.
 This report shall not be reproduced, except in full, without the written approval of the Issuing testing laboratory.
 Throughout this report a comma / point is used as the decimal separator.

Manufacturer's Declaration per sub-clause 6.2.5 of IEC 60950-1:	
The application for obtaining a CB Test Certificate includes more than one factory location and a declaration from the Manufacturer stating that the sample(s) submitted for evaluation is (are) representative of the products from each factory has been provided . :	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> Not applicable
When differences exist; they shall be identified in the General product information section.	
Name and address of factory (ies)	
1) Bel Power Solutions s.r.o ArealZTS Dubnica n.Vahom c.924 01841 Dubnica nad Vahom SLOVAKIA	3) Master Electronics 610 East 10th Street Oakland CA 94606 USA
2) Avnet Technology Solutions 6700 W Morelos Place Chandler AZ 85226 USA	4) Sonitrones S A De CV Arrow Electronics Inc. Boulevard Luis Donaldo Colosio 1179 84048 Nogales, Sonora MEXICO

General product information:

This test report is based on a TUV SUD test report Ref. No. SI1200012149-100 with appended CB cert Ref. No. DE 3 – 500643, evaluated to the requirements of IEC 60950-1:2005 2nd ed. + A1:2009.
 This test report includes an upgrade to IEC 60950-1:2005 (Second Edition) + Am 1:2009 + Am 2:2013, and addition evaluation of the power supply to the requirements of IT power systems and an engineering evaluation of the Leakage at the output of the PSU.
 For continuity, data from the original TUV report is included in this report, along with the additional evaluation referenced.
 The subject model is a component type AC-DC power supply for use in Information Technology Equipment. It consists of a complete metal enclosure, housing circuits operating at hazardous and SELV voltages.
 The unit is equipped on the front panel with an AC Input Connector and two status LED indicators; a cooling fan is mounted internally and protected by a fan guard.
 Internal assembly consists of the Main Board, control board and power modules of different types. Each module is provided with an isolating transformer and output busbar terminals for output connection, accessible at the back of the unit.

MODEL NOMENCLATURE MATRIX:

LPM	6	16	-	E	F	G	H	I	J	-	X
I	II	III		IV							V

- I – Product Series: LPM
- II – Number of slots: 6
- III – Maximum Output Power: 16 = 1600 W
- IV – Output Module:

Module	Model Name	Nominal Output Voltage (Vdc)	Voltage Range (Vdc)	Maximum Output Current (A)	Maximum Output Power (W)
E	LPM126-OUTA1-5	5	2.0 to 5.3	53	265
F	LPM126-OUTA1-12	12	5.2 to 15	22	265
G	LPM126-OUTA1-24	24	14 to 30	11	265
H	LPM126-OUTA1-36	36	29 to 44	7.4	265
J	LPM126-OUTA1-48	48	43 to 54	5.5	265
K	LPM109-OUTA1-10	10	1.5 to 15	6	90
L	LPM109-OUTA1-20	20	3 to 32	3	90
M	LPM118-OUTA2-10	10	2x 1.5 to 15	2x 6	2x 90
N	LPM118-OUTA2-20	20	2x 3 to 32	2 x 3	2x 90
0	Blank Panel Slot Cover				

Note: Any module may be placed on any slot location.

*Maximum output power of modules are derated based on operating ambient and input voltage. See below for details:

- 1) Module E: LPM126-OUTA1-5
Maximum 225 W for input voltage from 85-150 Vac, 40°C ambient
Maximum 175 W for input voltage from 85-264 Vac, 50 to 70°C ambient
- 2) Module F, G, H: LPM126-OUTA1-12, LPM126-OUTA1-24, LPM126-OUTA1-36
Maximum 225 W for input voltage from 85-150 Vac, 50°C ambient
Maximum 175 W for input voltage from 85-264 Vac 70°C ambient
- 3) Module K, L: LPM109-OUTA1-10, LPM109-OUTA1-20
Maximum 45 W for input voltage from 85-264 Vac 70°C ambient
- 4) Module M,N: LPM109-OUTA2-10, LPM118-OUTA2-20
Maximum 90 W for input voltage from 85-264 Vac 70°C ambient

V – Optional Suffixes: Denoting non-safety critical options

CONDITIONS OF ACCEPTABILITY:

The following must be evaluated at end use:

- 1) The power supply is to be installed only by trained service personnel, according to manufacturer installation instructions.
- 2) Evaluated for use in Pollution Degree 2 Environment, for a maximum ambient temperature of 40°C or 50°C (depending on module type(s) used and input ratings) at full load and 70°C at 50% load.
- 3) Temperature tests shall be considered for specific installation conditions in the end system.
- 4) Evaluated as Class I (earthed equipment). Reliable connection to protective earth shall be provided in the end use installation.
- 5) Spacings were evaluated for an operating altitude of max 10,000 ft (3048 m), based on IEC 60664-1 altitude correction factor.
- 6) Evaluated for connection to AC power with a branch circuit protector rated max 30 A. If used on a branch circuit with higher rating, additional testing shall be considered.
- 7) The front bezel has been evaluated and found compliant with requirements for FIRE, MECHANICAL and ELECTRICAL enclosure. Overall enclosure suitability is to be determined in the end system.
- 8) Output circuits in all modules are SELV and at hazardous energy levels (240 VA).
- 9) The input terminal block is suitable for field wiring.
- 10) The output connector was evaluated and is suitable only for factory wiring.

Abbreviations used in the report:

- normal conditions	N.C.	- single fault conditions	S.F.C
- functional insulation	OP	- basic insulation.....	BI
- double insulation.....	DI	- supplementary insulation.....	SI
- between parts of opposite polarity	BOP	- reinforced insulation	RI

Indicate used abbreviations (if any): None